

Town of Ledyard

Ledyard Public Schools

Sam Kilpatrick III  
Director Buildings and Grounds

## **Bidder Questions & Responses**

**Bid Proposal LPS-0047  
LHS Asbestos Abatement  
May 24th, 2019**

### **TO: ALL BIDDERS**

This document lists questions raised by bidders for Proposal LPS-0047, LHS Asbestos Abatement. A signed and dated copy of this Bidder Questions & Responses must accompany your bid proposal.

#### **Question 1. When can construction start? What is the school calendar?**

**Answer 1.** *The school calendar can be found on the district website: [www.ledyard.net](http://www.ledyard.net). High School Graduation is set for June 15, 2019. Construction can start as early as June 17, 2019, provided it has been authorized by CT DPH.*

#### **Question 2. If our company is DAS Prequalified, is it necessary to complete all sections regarding Qualifications?**

**Answer 2.** *As this is a State Reimbursable project, qualified companies **MUST have CT DAS Prequalification**. In addition, all sections of the bid form must be completed, as they are required by the Town of Ledyard.*

**Question 3.** You stated at the Mandatory Walk Through that there was a section of tunnel and a hatch missing from the diagram. Could you please indicate those on the attached sketch with dimensions?

**Answer 3.** *See Addendum B.*

**Question 4. How many linear feet of insulation should proposers include to be replaced?**

**Answer 4.** *Proposers should include replacement of 4200 linear feet of pipe insulation, and re-insulation of all pipe fittings to be abated. They should also include a price per linear foot for insulation. Upon completion of the abatement portion of this project, the contractor must verify exact amounts to be completed, and the cost will be adjusted based on the price/lf submitted.*